

# ENERGY AUDIT REPORT

of

## SHREE L. R. TIWARI COLLEGE OF LAW,

Shree L. R. Tiwari Educational Campus, Mira Road (East) Thane 401 107



Year: 2022-23


Prepared by:

### ENGRESS SERVICES


Yashashree, 26, Nirmal Bag Society,  
Near Mukhtangan English School, Parvati, Pune 411009  
Phone: 09890444795 Email: [engress123@gmail.com](mailto:engress123@gmail.com)



**REGISTRATION CERTIFICATES**




**AUDITOR CERTIFICATE**



**MEDA Registration Certificate**



**ISO: 9001-2015 Certificate**



**ISO: 14001-2015 Certificate**

## **INDEX**

<b>Sr. No</b>	<b>Particulars</b>	<b>Page No</b>
I	Acknowledgement	4
II	Executive Summary	5
III	Abbreviations	6
1	Introduction	7
2	Study of Connected Load	8
3	Study of Present Energy Consumption	9
4	Study of Energy Performance Index	10
5	Study of Lighting	11
6	Study of Renewable Energy & Energy Efficiency	13

## **ACKNOWLEDGEMENT**

We Engress Services, Pune, express our sincere gratitude to the management Shree L. R. Tiwari College of Law, Shree L. R. Tiwari Educational Campus, Mira Road (East) Thane 401 107, for awarding us the assignment of Energy Audit of their Campus for the Year: 2022-23.

We are thankful to all Staff members for helping us during the field study.

## EXECUTIVE SUMMARY

1. **Shree L. R. Tiwari College of Law, Mira Road**, consumes Energy in the form of **Electrical Energy**; used for various Electrical Equipment.

### 2. Present Connected Load & Energy Consumption:

No	Particulars	Value	Unit
1	Total Connected Load	95.76	kW
2	Annual Energy Consumed	66301	kWh

### 3. Energy Performance Index:

No	Particulars	Value	Unit
1	Total Annual Energy Consumed	38018	kWh
2	Total Built up area of college	3010	m <sup>2</sup>
3	Energy Performance Index = (1) / (2)	12.63	kWh/m <sup>2</sup>

### 4. Study of % Usage of LED Lighting:

No	Particulars	Value	Unit
1	% of Usage of LED Lighting to Total Lighting Load	100	%

### 5. Renewable Energy & Energy Efficiency Projects:

- Usage of Energy Efficient LED fittings
- Usage of BEE STAR Rated Energy Efficient Equipment

### 6. Assumptions:

1. **1 kWh** of Electrical Energy releases **0.9 Kg of CO<sub>2</sub>** into atmosphere
2. Energy Consumption is computed based on Load Utilization Factor

### 7. References:

- Audit Methodology: [www.mahaurja.com](http://www.mahaurja.com)
- Energy Conservation Building Code: ECBC-2017: [www.beeindia.gov.in](http://www.beeindia.gov.in)
- For CO<sub>2</sub> Emissions: [www.tatapower.com](http://www.tatapower.com)

## **ABBREVIATIONS**

LED	:	Light Emitting Diode
BEE	:	Bureau of Energy Efficiency
FTL	:	Fluorescent Tube Light
CFL	:	Compact Fluorescent Light
PV	:	Photo Voltaic
Kg	:	Kilo Gram
kWh	:	kilo-Watt Hour
CO <sub>2</sub>	:	Carbon Di Oxide
MT	:	Metric Ton

## CHAPTER-I INTRODUCTION


### 1.1 Introduction:

An Energy Audit is conducted at Shree L. R. Tiwari College of Law, Mira Road (East) Thane 401 107.


The guidelines followed for conducting the Energy Audit are:

- BEE India's Energy Conservation Building Code: ECBC-2017
- Maharashtra Energy Development Agency ([www.mahaurja.com](http://www.mahaurja.com))
- Tata Power: [www.tatapower.com](http://www.tatapower.com)

### 1.2 Audit Procedural Steps:



### 1.3 Google Earth Image:



College  
Campus


## CHAPTER-II STUDY OF CONNECTED LOAD

The major contributors to the connected load of the College include:

**Table No 1: Study of Equipment wise Connected Load:**

No	Equipment	Qty	Load, W/unit	Load, kW
1	16 W LED fittings	149	16	2.384
2	40 W LED Fittings	5	40	0.2
3	Ceiling Fan	374	65	24.31
4	P C	12	150	1.8
5	Printer	2	175	0.35
6	1.5 TR A C	4	1800	7.2
7	Water Pump	1	2400	2.4
8	Water Cooler	2	350	0.7
9	Other Equipment	25	250	6.25
10	<b>Total</b>			<b>45.59</b>

**Chart No 1: Study of Connected Load:**






## CHAPTER-III STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of last year Electricity Bills

**Table No 2: Electrical Bill Analysis- 2022-23:**

No	Month	Energy Consumed, kWh	CO <sub>2</sub> Emissions, MT
1	Jul-22	3360	3.02
2	Aug-22	3118	2.81
3	Sep-22	2978	2.68
4	Oct-22	3069	2.76
5	Nov-22	3116	2.80
6	Dec-22	3229	2.91
7	Jan-23	3157	2.84
8	Feb-23	3489	3.14
9	Mar-23	3009	2.71
10	Apr-23	2978	2.68
11	May-23	3118	2.81
12	Jun-23	3397	3.06
13	Total	38018	34.22
14	Maximum	3489	3.14
15	Minimum	2978	2.68
16	Average	3168.17	2.85

**Chart No 2: Variation in Monthly Energy Consumption:**



## **CHAPTER-IV**

### **STUDY OF ENERGY PERFORMANCE INDEX**

**Energy Performance Index:** Energy Performance Index of a Building is its Annual Energy Consumption in Kilo Watt Hours per square meter of the Building

It is determined by:

$$\text{EPI} = \frac{\text{(Annual Energy Consumption in kWh)}}{\text{(Total Built-up area in m}^2\text{)}}$$

Now we compute the EPI for the College as under:

**Table No 3: Computation of Energy Performance Index:**

<b>No</b>	<b>Particulars</b>	<b>Value</b>	<b>Unit</b>
1	Total Annual Energy Purchased	<b>38018</b>	kWh
2	Total Built up area of College	<b>3010</b>	m <sup>2</sup>
<b>3</b>	Energy Performance Index = (1) / (2)	<b>12.63</b>	kWh/m <sup>2</sup>

## CHAPTER-V STUDY OF LIGHTING

### Terminology:

1. **Lumen** is a unit of light flow or luminous flux. The lumen rating of a lamp is a measure of the total light output of the lamp. The most common measurement of light output (or luminous flux) is the lumen. Light sources are labeled with an output rating in lumens.

2. **Lux** is the metric unit of measure for illuminance of a surface. One lux is equal to one lumen per square meter.

3. **Circuit Watts** is the total power drawn by lamps and ballasts in a lighting circuit under assessment.

4. **Installed Load Efficacy** is the average maintained illuminance provided on a horizontal working plane per circuit watt with general lighting of an interior. Unit: lux per watt per square metre (lux/W/m<sup>2</sup>)

5. **Lamp Circuit Efficacy** is the amount of light (lumens) emitted by a lamp for each watt of power consumed by the lamp circuit, i.e. including control gear losses. This is a more meaningful measure for those lamps that require control gear. Unit: lumens per circuit watt (lm/W)

6. **Installed Power Density.** The installed power density per 100 lux is the power needed per square metre of floor area to achieve 100 lux of average maintained illuminance on a horizontal working plane with general lighting of an interior. Unit: watts per square metre per 100 lux (W/m<sup>2</sup>/100 lux) 100 Installed power density (W/m<sup>2</sup>/100 lux)

7. **Lighting Power Density:** It is defined as Total Lighting Load in a room divided by the Area of that Room in square meters.

In this Chapter we compute the percentage usage of LED Lighting to total Lighting Load of the College.

**Table No 4: Percentage Usage of LED Lighting to Total Lighting Load:**

No	Particulars	Value	Unit
1	No of 16 W LED Fittings	630	Nos
2	Load of 16 W LED Fitting	16	W/unit
3	Total Load of 16 W LED Fittings	10.08	kW
4	No of 40 W LED Fittings	5	Nos
5	Load of 40 W LED Fitting	40	W/unit

<b>6</b>	Total Load of 40 W LED Fittings	<b>0.2</b>	kW
<b>7</b>	Total LED Lighting Load= 3+6	<b>10.28</b>	kW
<b>8</b>	Total Lighting Load= 3+6	<b>10.28</b>	kW
<b>9</b>	% of LEDs to Total Lighting Load = $7 \times 100 / 8$	<b>100</b>	%

## **CHAPTER-V**

### **STUDY OF RENEWABLE ENERGY & ENERGY EFFICIENCY**

#### **5.1 Usage of Renewable Energy:**

- The College has yet to install Roof Top Solar PV Plant

#### **5.2 Energy Efficiency Projects:**

- Usage of Energy Efficient LED Lighting
- Usage of Energy Efficient BEE STAR Rated Equipment

#### **Photographs of LED Lighting & STAR Rated AC:**

